



City of Oviedo Fire/Rescue

400 Alexandria Blvd, Oviedo Florida 32765
Physical Location: 1934 West CR 419, Oviedo FL, 32766

The following requirements are outlined in the Florida Fire Prevention Code 5th Edition and shall be adhered to when cooking under a tent or in fixed, mobile or temporary concession, such as trucks, buses, trailers within the City of Oviedo limits.

GENERAL REQUIREMENTS **FOR FOOD VENDORS**

Due to DBPR regulations and Florida Administrative Code 61C-4.016 all cooking and food preparations shall be done under cover. If cooking under a tent or within a fixed, mobile, or temporary concession the following requirements shall be adhered to, otherwise operations will immediately cease.

When cooking under a tent/canopy like structure, the structure shall be an approved flame resistant material compliant with NFPA 701 standards. **The label shall be permanently affixed to the tent showing the fire resistant treatment or rating approval.** If utilizing a non-compliant tent/canopy like structure the cooking operation shall be conducted outside of the structure and a minimum 10 feet away.

Cooking equipment in fixed, mobile, or temporary concessions, such as trucks, buses, trailers, in which cooking equipment produces grease laden vapors shall have a professionally certified NFPA 96 fire suppression system installed. This system must also be up to date with inspections (every 6 months)

When cooking under a tent/canopy like structure the structure shall have a minimum (1) one 2A-10BC fire extinguisher.

When cooking involves equipment producing grease laden vapors a Class K fire extinguisher shall be provided in addition to the 2A-10BC fire extinguisher.

All fire extinguishers, to include new store bought types shall be serviced and tagged annually by a licensed State of Florida fire extinguisher contractor. To help assist with locating local licensed fire extinguishers contractors you may conduct an online search or yellow pages.

Important- Fire extinguishers purchased from a hardware store do not come tagged by a licensed State of Florida fire extinguisher contractor; therefore you will need to contact a local licensed fire extinguisher contractor for this service.

Deep fat fryers or pans with grease used for cooking shall have a metal cover plate, (lid) to put on them in case of fire or rain.

All propane cylinders must be secured. Small cylinders (20lbs) can be place in a milk carton or any other carton type crate. Larger cylinders shall be secured to a stationary object, (fence, pole, etc.) except personal type grills with propane cylinders attached.

All propane cylinders (other than personal type grills with propane cylinders attached) shall be 10 feet from the cooking appliance with gas line(s) secured.

The filling of gas tanks on site is strictly prohibited.

There shall be no access to any of the cooking appliances by the general public.

No cooking or gas powered appliances of any type, shall be used within 10 feet of any occupied building or any part of the building's overhang.

***I have read and will comply with the requirements as listed above.
Failure to do so will result in further action.***

Company Name _____ Contact Name _____

Address _____ City _____ State _____ Zip _____

Contact Number _____ Contact Email _____

Signature _____ Date _____

These requirements do not circumvent any other departmental requirements. Failure to adhere to the above requirements shall result in the immediate operation to cease.

Please complete this form in its entirety and return to the City of Oviedo Fire Prevention Division no later than (3) three business days prior to the scheduled event.

Completed forms shall be provided to the event host and emailed to sginsburg@cityofoviedo.net and/or abaumann@cityofoviedo.net or faxed to 407-971-5810.